

- Are fiber or cat 6 patch cables required as a part of the bid for any of Reynolds' e-rate projects?
 - No, patch cables will be supplied by Reynolds School District
- For the Station Cabling project, what are the cable counts per school?
 - Glenfair has 115 cables, Hartley has 80 cables, Margaret Scott has 140 cables
- For the Station Cabling project, will any site need fiber pulled/terminated or is it strictly Cat6?
 - It is strictly Cat6 cabling, no fiber work is required
- What is the correct number of lab fiber and lab wall mount enclosures at Reynolds H.S.?
 - The correct number of labs is 5 for the lab fiber and wall mount enclosures at R.H.S.. The documentation states 8 but this is incorrect.