

Fairview Elementary School - Radon Testing Results

Kit Number	Start Date	Start Time	End Date	End Time	Temperature	Facility	Building	Room	Project ID	Floor	Result	Variance	Analysis Notes	Analysis Date	%Moisture
9120132	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 161	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	3.6
9120114	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 144	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120129	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	150 MAIN	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120111	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 114	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.5
9120142	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	MUSIC ROOM	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120108	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	HEALTH ROOM	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120103	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 108	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120124	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 162	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.2
9120139	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 150A	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120121	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 160A DUP	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120136	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 151	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120118	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	RM 160A BLANK	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.2
9120133	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 150A BLANK	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.3
9120115	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 143	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.5
9120130	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	140 MAIN	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.1
9120112	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 140A DUP	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120143	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	GYM 2	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.1
9120109	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	MAIN OFFICE	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.3
9120105	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 111	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120125	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	CUST. OFF. DUP	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.3
9120140	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 154	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	3.6
9120101	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 102	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120122	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 164	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120119	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 160A	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120134	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 150A DUP	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.3
9120116	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 142	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	5.3
9120131	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	160 MAIN	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	3.6
9120147	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	P. E. OFFICE	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120113	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 140A	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.5
9120110	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 107	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120106	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 100B	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120126	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	CUSTODIAL OFFICE	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120141	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 153	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.3
9120107	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 101A	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	5.2
9120102	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 103	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120123	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 163	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
9120120	2019-03-05	4:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	CAFETERIA 1	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.5
9120135	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 152	REYNOLDS SD	1	< 0.3	0.4		2019-03-11	4.4
9120117	2019-03-05	3:00 pm	2019-03-08	4:00 pm	70	FAIRVIEW	MAIN	ROOM 141	REYNOLDS SD	1	< 0.3	0.3		2019-03-11	4.4
7249096	2019-03-19	5:00 pm	2019-03-22	2:00 pm	70	FAIRVIEW	MAIN	CAFETERIA 1	REYNOLDS SD	1		0.5		2019-03-25	4.4
7249097	2019-03-19	5:00 pm	2019-03-22	2:00 pm	70	FAIRVIEW	MAIN	GYM 1	REYNOLDS SD	1		0.6	0.3	2019-03-25	4.5
						FAIRVIEW	MAIN	ROOM 242	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 241	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 243	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 244	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 251	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 252	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 253	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 254	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 261	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 262	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 263	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	ROOM 264	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				
						FAIRVIEW	MAIN	LIBRARY	REYNOLDS SD	2	NOT SAMPLED - SECOND FLOOR				