

Reynolds Middle School - Radon Testing Results (Follow-up)

Kit Number	Start Date	Start Time	End Date	End Time	Temperature	Facility	Building	Room	Project ID	Floor	Result	Variance	Analysis Notes	Analysis Date	%Moisture
9014740	2019-03-11	3:00 pm	2019-03-14	2:00 pm	70	REYNOLDS MIDDLE SCHOOL	MAIN	CUSTOD. OFF. DUP	REYNOLDS SCHOOL DISTRICT	1	12.9	1.3		2019-03-18	8.9
9014744	2019-03-11	3:00 pm	2019-03-14	2:00 pm	70	REYNOLDS MIDDLE SCHOOL	MAIN	CUST. OFF. BLANK	REYNOLDS SCHOOL DISTRICT	1	< 0.3	0.4		2019-03-18	6.7
9014900	2019-03-11	3:00 pm	2019-03-14	2:00 pm	70	REYNOLDS MIDDLE SCHOOL	MAIN	CUSTODIAL OFFICE	REYNOLDS SCHOOL DISTRICT	1	12.5	1.2		2019-03-18	9.6