

Troutdale Elementary School - Radon Testing Results

Kit Number	Start Date	Start Time	End Date	End Time	Temperature	Facility	Building	Room	Project ID	Floor	Result	Variance	Analysis Notes	Analysis Date	%Moisture
9196643	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	MUSIC ROOM	REYNOLDS SD	1		0.5	0.3	2019-04-09	6.8
9196665	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 161	REYNOLDS SD	1		0.5	0.3	2019-04-09	5.1
9196645	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 107	REYNOLDS SD	1		0.6	0.3	2019-04-09	5.3
9196644	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	GYM OFFICE	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.9
9196646	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 108	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.3
9196647	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 104	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.3
9196648	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	CAFETERIA 1	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6.1
9196649	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	CAFETERIA 2	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6
9196650	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	GYM 1	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.2
9196651	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 140A	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6
9196652	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	GYM 2	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6
9196653	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 160A DUP	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	4.5
9196654	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 100E BLANK	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	3.6
9196655	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 153	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.2
9196656	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 140A DUP	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6
9196657	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 144	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.2
9196658	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 142	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6
9196659	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 150	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.2
9196660	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 103	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.9
9196661	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 140	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6
9196662	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	CUSTODIAL OFFICE	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6.7
9196663	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 143	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.3
9196664	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 160	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.2
9196666	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 100C	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.1
9196667	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 100D	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.9
9196668	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 100E	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.1
9196669	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	RM 100E DUP	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6
9196670	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 162	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.2
9196671	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 163	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	4.5
9196672	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 164	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6.1
9196673	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 141	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	5.2
9196674	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 154	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	4.5
9196675	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 152	REYNOLDS SD	1	< 0.3		0.3	2019-04-09	6
9196677	2019-04-02	6:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 151	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6.1
9196678	2019-04-02	6:00 pm	2019-04-05	8:00 pm	70	TROUTDALE	MAIN	ROOM 150A	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	6.1
9196679	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	ROOM 160A	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.3
9196680	2019-04-02	5:00 pm	2019-04-05	7:00 pm	70	TROUTDALE	MAIN	MAIN OFFICE	REYNOLDS SD	1	< 0.3		0.4	2019-04-09	5.3
						TROUTDALE	MAIN	LIBRARY	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	LIBRARY OFFICE	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 240	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 241	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 242	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 243	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 244	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 245	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 246	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 207	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 208	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 209	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 250	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 251	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 252	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 253	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 254	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 255	REYNOLDS SD		NOT TESTED - SECOND FLOOR				

						TROUTDALE	MAIN	ROOM 256	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 260	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 261	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 262	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 263	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 264	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 265	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 266	REYNOLDS SD		NOT TESTED - SECOND FLOOR				
						TROUTDALE	MAIN	ROOM 206	REYNOLDS SD		NOT TESTED - SECOND FLOOR				