



Reynolds School District
 Administration Offices
 1204 NE 201st Avenue
 Fairview, OR 97024
 503.661.7200 • FAX 503.667.6932

Margaret Scott First Round Water Testing June 2016

Sample ID	RESULT	ug/L
SCOTT01	TESTED BUT NOT POTABLE - RESULTS DEEMED UNNECESSARY	155 UG/L
SCOTT02	FAIL	107 ug/L
SCOTT03	PASS	
SCOTT04	FAIL	38.1 ug/L
SCOTT05	FAIL	114 ug/L
SCOTT06	FAIL	135 ug/L
SCOTT07	FAIL	40.8 ug/L
SCOTT08	FAIL	195 ug/L
SCOTT09	FAIL	29.3 ug/L
SCOTT10	FAIL	33.6 ug/L
SCOTT11	PASS	
SCOTT12	BOTTLES NOT USED	
SCOTT13		
SCOTT14		
SCOTT15		
SCOTT15		



Reynolds School District
Administration Offices
1204 NE 201st Avenue
Fairview, OR 97024
503.661.7200 • FAX 503.667.6932

Margaret Scott First Round Water Testing June 2016

Sample ID	RESULT	ug/L
SCOTT16	PASS	
SCOTT17	PASS	
SCOTT18	FAIL	20.2 ug/L
SCOTT19	PASS	
SCOTT20	PASS	
SCOTT21	PASS	
SCOTT22	PASS	
SCOTT23	FAIL	32.9 ug/L
SCOTT24	FAIL	43.5 ug/L
SCOTT25	PASS	
SCOTT26	FAIL	65.8 ug/L
SCOTT27	FAIL	20.3 ug/L
SCOTT28	FAIL	42.2 ug/L
SCOTT29	PASS	
SCOTT30	PASS	



Reynolds School District
Administration Offices
1204 NE 201st Avenue
Fairview, OR 97024
503.661.7200 • FAX 503.667.6932

Margaret Scott First Round Water Testing June 2016

Sample ID	RESULT	ug/L
SCOTT31	PASS	
SCOTT32		
SCOTT33		
SCOTT34		
SCOTT35		
SCOTT36		
SCOTT37		
SCOTT38		
SCOTT39		
SCOTT40		
SCOTT41		
SCOTT42		
SCOTT43		
SCOTT44		
SCOTT45		

BOTTLES NOT USED



Reynolds School District
 Administration Offices
 1204 NE 201st Avenue
 Fairview, OR 97024
 503.661.7200 • FAX 503.667.6932

Margaret Scott Water Testing June 2016

Sampled By: Diane Spangler 06/13/16

Sample ID	Location (Classroom# or Faucet Loc.)	Date
SCOTT01	Kitchen Dishwashing Sink	6/13/16 22:28
SCOTT02	Room 12 Drinking Fountain on Sink	6/13/16 22:34
SCOTT03	Room 14 Drinking Fountain on Sink	6/13/16 22:39
SCOTT04	Room 1 Drinking Fountain on Sink	6/13/16 22:46
SCOTT05	Room 2 Drinking Fountain on Sink	6/13/16 22:49
SCOTT06	Room 3 Drinking Fountain on Sink	6/13/16 22:53
SCOTT07	Room 4 Drinking Fountain on Sink	6/13/16 22:58
SCOTT08	Room 5 Drinking Fountain on Sink	6/13/16 23:02
SCOTT09	Counselor's office on East End of library by Computer Lab. South Door. <small>wasn't posted</small>	6/13/16 23:07
SCOTT10	Gym Drinking fountain left side shorter (West)	6/13/16 23:14
SCOTT11	Gym Drinking fountain right side taller (East)	6/13/16 23:14
SCOTT12	~~~~~ END ~~~~~	}
SCOTT13		
SCOTT14		
SCOTT15		

Entered by 6/14/16 @ 0908



Reynolds School District
 Administration Offices
 1204 NE 201st Avenue
 Fairview, OR 97024
 503.661.7200 • FAX 503.667.6932

Margaret Scott Water Testing June 2016

Sampled By: Lawrence Spangler

Sample ID	Location (Classroom# or Faucet Loc.)	Date
SCOTT16	M. Scott Nurse Station / Office 10:20 pm	6-13-2016
SCOTT17	M. Scott Staff Lounge 10:23 pm	6-13-2016
SCOTT18	M. Scott Kitchen south sink 10:25 pm	6-13-2016
SCOTT19	M. Scott " North sink 10:27 pm	6-13-2016
SCOTT20	M. Scott cafe East water fountain 10:29 pm	6-13-2016
SCOTT21	M. Scott " Battle fill station 10:30 pm	6-13-2016
SCOTT22	M. Scott " West water fountain 10:31 pm	6-13-2016
SCOTT23	M. Scott Rm 11 Drinking fountain 10:35 pm	6-13-2016
SCOTT24	M. Scott Rm 13 " 10:40 pm	6-13-2016
SCOTT25	M. Scott Rm 10 " 10:50 pm	6-13-2016
SCOTT26	M. Scott Rm 9 " 10:51 pm	6-13-2016
SCOTT27	M. Scott Rm 8 " 10:52 pm	6-13-2016
SCOTT28	M. Scott Rm 6 " 10:53 pm	6-13-2016
SCOTT29	M. Scott Rm 7 " 10:55 pm	6-13-2016
SCOTT30	M. Scott Rm 19 portable DF 10:57 pm	6-13-2016



Reynolds School District
Administration Offices
1204 NE 201st Avenue
Fairview, OR 97024
503.661.7200 • FAX 503.667.6932

Margaret Scott Water Testing June 2016

Sampled By: Lawrence Spangler

Sample ID	Location (Classroom# or Faucet Loc.)	Date
SCOTT31	M. Scott portable Dual Drinking Fountain #10 11/16	6-13-2016
SCOTT32		
SCOTT33		
SCOTT34		
SCOTT35		
SCOTT36		
SCOTT37		
SCOTT38		
SCOTT39		
SCOTT40		
SCOTT41		
SCOTT42		
SCOTT43		
SCOTT44		
SCOTT45		

Apex Labs

12232 S.W. Garden Place
Tigard, OR 97223
503-718-2323 Phone
503-718-0333 Fax

Tuesday, July 5, 2016

Rich Dufresne
PBS Engineering and Environmental
4412 SW Corbett Ave
Portland, OR 97239

RE: Reynolds School-Scott / Reynolds SD #7 / PR23514.022

Enclosed are the results of analyses for work order A6F0688, which was received by the laboratory on 6/21/2016 at 10:10:00AM.

Thank you for using Apex Labs. We appreciate your business and strive to provide the highest quality services to the environmental industry.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: ldomenighini@apex-labs.com, or by phone at 503-718-2323.

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Lisa Domenighini, Client Services Manager

PBS Engineering and Environmental

4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**

Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Scott 01	A6F0688-01	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 02	A6F0688-02	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 03	A6F0688-03	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 04	A6F0688-04	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 05	A6F0688-05	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 06	A6F0688-06	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 07	A6F0688-07	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 08	A6F0688-08	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 09	A6F0688-09	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 10	A6F0688-10	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 11	A6F0688-11	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 16	A6F0688-12	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 17	A6F0688-13	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 18	A6F0688-14	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 19	A6F0688-15	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 20	A6F0688-16	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 21	A6F0688-17	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 22	A6F0688-18	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 23	A6F0688-19	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 24	A6F0688-20	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 25	A6F0688-21	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 26	A6F0688-22	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 27	A6F0688-23	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 28	A6F0688-24	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 29	A6F0688-25	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 30	A6F0688-26	Drinking Water	06/13/16 00:00	06/21/16 10:10
Scott 31	A6F0688-27	Drinking Water	06/13/16 00:00	06/21/16 10:10

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental

4412 SW Corbett Ave
Portland, OR 97239

Project: **Reynolds School-Scott**

Project Number: Reynolds SD #7 / PR23514.0
Project Manager: Rich Dufresne

Reported:

07/05/16 08:36

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting		Dilution	Date Analyzed	Method	Notes
			Limit	Units				
Scott 01 (A6F0688-01)			Matrix: Drinking Water					
Batch: 6060872								
Lead	19.9	---	0.200	ug/L	1	06/30/16 14:42	EPA 200.8	
Scott 02 (A6F0688-02)			Matrix: Drinking Water					
Batch: 6060872								
Lead	107	---	0.200	ug/L	1	06/30/16 14:43	EPA 200.8	
Scott 03 (A6F0688-03)			Matrix: Drinking Water					
Batch: 6060872								
Lead	18.1	---	0.200	ug/L	1	06/30/16 14:45	EPA 200.8	
Scott 04 (A6F0688-04)			Matrix: Drinking Water					
Batch: 6060872								
Lead	38.1	---	0.200	ug/L	1	06/30/16 14:48	EPA 200.8	
Scott 05 (A6F0688-05)			Matrix: Drinking Water					
Batch: 6060872								
Lead	114	---	0.200	ug/L	1	06/30/16 14:50	EPA 200.8	
Scott 06 (A6F0688-06)			Matrix: Drinking Water					
Batch: 6060871								
Lead	135	---	0.200	ug/L	1	06/30/16 13:56	EPA 200.8	
Scott 07 (A6F0688-07)			Matrix: Drinking Water					
Batch: 6060872								
Lead	40.8	---	0.200	ug/L	1	06/30/16 14:52	EPA 200.8	
Scott 08 (A6F0688-08)			Matrix: Drinking Water					
Batch: 6060933								
Lead	195	---	0.200	ug/L	1	06/30/16 20:36	EPA 200.8	
Scott 09 (A6F0688-09)			Matrix: Drinking Water					
Batch: 6060920								
Lead	29.3	---	0.200	ug/L	1	06/30/16 15:40	EPA 200.8	
Scott 10 (A6F0688-10)			Matrix: Drinking Water					
Batch: 6060920								
Lead	33.6	---	0.200	ug/L	1	06/30/16 15:43	EPA 200.8	
Scott 11 (A6F0688-11)			Matrix: Drinking Water					
Batch: 6060920								
Lead	17.6	---	0.200	ug/L	1	06/30/16 15:45	EPA 200.8	
Scott 16 (A6F0688-12)			Matrix: Drinking Water					

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental
 4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**
 Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting		Dilution	Date Analyzed	Method	Notes
			Limit	Units				
Scott 16 (A6F0688-12)			Matrix: Drinking Water					
Batch: 6060920								
Lead	1.71	---	0.200	ug/L	1	06/30/16 15:47	EPA 200.8	
Scott 17 (A6F0688-13)			Matrix: Drinking Water					
Batch: 6060920								
Lead	1.29	---	0.200	ug/L	1	06/30/16 15:48	EPA 200.8	
Scott 18 (A6F0688-14)			Matrix: Drinking Water					
Batch: 6060920								
Lead	20.2	---	0.200	ug/L	1	06/30/16 15:53	EPA 200.8	
Scott 19 (A6F0688-15)			Matrix: Drinking Water					
Batch: 6060920								
Lead	1.64	---	0.200	ug/L	1	06/30/16 15:54	EPA 200.8	
Scott 20 (A6F0688-16)			Matrix: Drinking Water					
Batch: 6060920								
Lead	ND	---	0.200	ug/L	1	06/30/16 15:56	EPA 200.8	
Scott 21 (A6F0688-17)			Matrix: Drinking Water					
Batch: 6060920								
Lead	ND	---	0.200	ug/L	1	06/30/16 15:57	EPA 200.8	
Scott 22 (A6F0688-18)			Matrix: Drinking Water					
Batch: 6060920								
Lead	ND	---	0.200	ug/L	1	06/30/16 15:59	EPA 200.8	
Scott 23 (A6F0688-19)			Matrix: Drinking Water					
Batch: 6060920								
Lead	32.9	---	0.200	ug/L	1	06/30/16 16:00	EPA 200.8	
Scott 24 (A6F0688-20)			Matrix: Drinking Water					
Batch: 6060920								
Lead	43.5	---	0.200	ug/L	1	06/30/16 16:02	EPA 200.8	
Scott 25 (A6F0688-21)			Matrix: Drinking Water					
Batch: 6060920								
Lead	3.91	---	0.200	ug/L	1	06/30/16 16:03	EPA 200.8	
Scott 26 (A6F0688-22)			Matrix: Drinking Water					
Batch: 6060920								
Lead	65.8	---	0.200	ug/L	1	06/30/16 16:05	EPA 200.8	
Scott 27 (A6F0688-23)			Matrix: Drinking Water					

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental
 4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**
 Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting		Dilution	Date Analyzed	Method	Notes
			Limit	Units				
Scott 27 (A6F0688-23)			Matrix: Drinking Water					
Batch: 6060920								
Lead	20.3	---	0.200	ug/L	1	06/30/16 16:20	EPA 200.8	
Scott 28 (A6F0688-24)			Matrix: Drinking Water					
Batch: 6060920								
Lead	42.2	---	0.200	ug/L	1	06/30/16 16:11	EPA 200.8	
Scott 29 (A6F0688-25)			Matrix: Drinking Water					
Batch: 6060920								
Lead	2.68	---	0.200	ug/L	1	06/30/16 16:12	EPA 200.8	
Scott 30 (A6F0688-26)			Matrix: Drinking Water					
Batch: 6060920								
Lead	ND	---	0.200	ug/L	1	06/30/16 16:21	EPA 200.8	
Scott 31 (A6F0688-27)			Matrix: Drinking Water					
Batch: 6060933								
Lead	13.1	---	0.200	ug/L	1	06/30/16 20:41	EPA 200.8	

Apex Laboratories



Lisa Domenighini, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental
4412 SW Corbett Ave
Portland, OR 97239

Project: **Reynolds School-Scott**
Project Number: Reynolds SD #7 / PR23514.0
Project Manager: Rich Dufresne

Reported:
07/05/16 08:36

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting Limit	Units	Dil.	Spike Amount	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch 6060871 - Matrix Matched Direct Inject						Drinking Water						
Blank (6060871-BLK1)						Prepared: 06/29/16 12:13 Analyzed: 06/30/16 13:53						
EPA 200.8												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	---
LCS (6060871-BS1)						Prepared: 06/29/16 12:13 Analyzed: 06/30/16 13:54						
EPA 200.8												
Lead	17.2	---	0.200	ug/L	1	16.7	---	103	85-115%	---	---	---
Batch 6060872 - Matrix Matched Direct Inject						Drinking Water						
Blank (6060872-BLK1)						Prepared: 06/29/16 12:15 Analyzed: 06/30/16 14:39						
EPA 200.8												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	---
LCS (6060872-BS1)						Prepared: 06/29/16 12:15 Analyzed: 06/30/16 14:40						
EPA 200.8												
Lead	16.7	---	0.200	ug/L	1	16.7	---	100	85-115%	---	---	---
Duplicate (6060872-DUP1)						Prepared: 06/29/16 12:15 Analyzed: 06/30/16 14:46						
QC Source Sample: Scott 03 (A6F0688-03)												
EPA 200.8												
Lead	17.1	---	0.200	ug/L	1	---	18.1	---	---	6	20%	---
Matrix Spike (6060872-MS1)						Prepared: 06/29/16 12:15 Analyzed: 06/30/16 14:49						
QC Source Sample: Scott 04 (A6F0688-04)												
EPA 200.8												
Lead	53.7	---	0.200	ug/L	1	16.7	38.1	93	70-130%	---	---	---



PBS Engineering and Environmental
 4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**
 Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting Limit	Units	Dil.	Spike Amount	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch 6060920 - Matrix Matched Direct Inject						Drinking Water						
Blank (6060920-BLK1)						Prepared: 06/30/16 12:24 Analyzed: 06/30/16 15:28						
EPA 200.8												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	---
LCS (6060920-BS1)						Prepared: 06/30/16 12:24 Analyzed: 06/30/16 15:29						
EPA 200.8												
Lead	15.9	---	0.200	ug/L	1	16.7	---	96	85-115%	---	---	---
Duplicate (6060920-DUP1)						Prepared: 06/30/16 12:24 Analyzed: 06/30/16 15:41						
QC Source Sample: Scott 09 (A6F0688-09)												
EPA 200.8												
Lead	28.0	---	0.200	ug/L	1	---	29.3	---	---	5	20%	---
Matrix Spike (6060920-MS1)						Prepared: 06/30/16 12:24 Analyzed: 06/30/16 15:44						
QC Source Sample: Scott 10 (A6F0688-10)												
EPA 200.8												
Lead	51.6	---	0.200	ug/L	1	16.7	33.6	108	70-130%	---	---	---
Matrix Spike (6060920-MS2)						Prepared: 06/30/16 12:24 Analyzed: 06/30/16 16:15						
QC Source Sample: Scott 30 (A6F0688-26)												
EPA 200.8												
Lead	16.2	---	0.200	ug/L	1	16.7	ND	97	70-130%	---	---	---

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Lisa Domenighini, Client Services Manager

PBS Engineering and Environmental
 4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**
 Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	MDL	Reporting Limit	Units	Dil.	Spike Amount	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch 6060933 - EPA 3015A						Drinking Water						
Blank (6060933-BLK1)						Prepared: 06/30/16 15:24 Analyzed: 06/30/16 20:01						
EPA 200.8												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	---
LCS (6060933-BS1)						Prepared: 06/30/16 15:24 Analyzed: 06/30/16 20:03						
EPA 200.8												
Lead	17.2	---	0.200	ug/L	1	16.7	---	103	85-115%	---	---	---

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Lisa Domenighini, Client Services Manager

PBS Engineering and Environmental

4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**

Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:

07/05/16 08:36

SAMPLE PREPARATION INFORMATION

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Prep: EPA 3015A

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
Batch: 6060933							
A6F0688-08	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 15:24	45mL/50mL	45mL/50mL	1.00
A6F0688-27	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 15:24	45mL/50mL	45mL/50mL	1.00

Prep: Matrix Matched Direct Inject

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
Batch: 6060871							
A6F0688-06	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:13	45mL/50mL	45mL/50mL	1.00
Batch: 6060872							
A6F0688-01	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
A6F0688-02	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
A6F0688-03	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
A6F0688-04	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
A6F0688-05	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
A6F0688-07	Drinking Wa	EPA 200.8	06/13/16 00:00	06/29/16 12:15	45mL/50mL	45mL/50mL	1.00
Batch: 6060920							
A6F0688-09	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-10	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-11	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-12	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-13	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-14	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-15	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-16	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-17	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-18	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-19	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-20	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-21	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-22	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-23	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-24	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-25	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00
A6F0688-26	Drinking Wa	EPA 200.8	06/13/16 00:00	06/30/16 12:24	45mL/50mL	45mL/50mL	1.00

Apex Laboratories



The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental

4412 SW Corbett Ave
Portland, OR 97239

Project: **Reynolds School-Scott**

Project Number: Reynolds SD #7 / PR23514.0
Project Manager: Rich Dufresne

Reported:

07/05/16 08:36

Notes and Definitions

Qualifiers:

Notes and Conventions:

- DET Analyte DETECTED
- ND Analyte NOT DETECTED at or above the reporting limit
- NR Not Reported
- dry Sample results reported on a dry weight basis. Results listed as 'wet' or without 'dry' designation are not dry weight corrected.
- RPD Relative Percent Difference
- MDL If MDL is not listed, data has been evaluated to the Method Reporting Limit only.
- WMSC Water Miscible Solvent Correction has been applied to Results and MRLs for volatiles soil samples per EPA 8000C.
- Batch QC Unless specifically requested, this report contains only results for Batch QC derived from client samples included in this report. All analyses were performed with the appropriate Batch QC (including Sample Duplicates, Matrix Spikes and/or Matrix Spike Duplicates) in order to meet or exceed method and regulatory requirements. Any exceptions to this will be qualified in this report. Complete Batch QC results are available upon request. In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) is analyzed to demonstrate accuracy and precision of the extraction and analysis.
- Blank Policy Apex assesses blank data for potential high bias down to a level equal to 1/2 the method reporting limit (MRL), except for conventional chemistry and HCID analyses which are assessed only to the MRL. Sample results flagged with a B or B-02 qualifier are potentially biased high if they are less than ten times the level found in the blank for inorganic analyses or less than five times the level found in the blank for organic analyses.
- For accurate comparison of volatile results to the level found in the blank; water sample results should be divided by the dilution factor, and soil sample results should be divided by 1/50 of the sample dilution to account for the sample prep factor.
- Results qualified as reported below the MRL may include a potential high bias if associated with a B or B-02 qualified blank. B and B-02 qualifications are not applied to J qualified results reported below the MRL.
- QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.
- *** Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

PBS Engineering and Environmental
4412 SW Corbett Ave
Portland, OR 97239

Project: **Reynolds School-Scott**
Project Number: Reynolds SD #7 / PR23514.0
Project Manager: Rich Dufresne

Reported:
07/05/16 08:36

CHAIN OF CUSTODY

Company: **PBS** Project Mgr: **Ayanna Caloyer** Project Name: **Reynolds SD #7** Project #/PO#: **PR23514.002**
 12232 S.W. Garden Place, Tigard, OR 97223 Phone: (503) 248-1939 Fax: Email: **aglover@rsd7.net**
 4412 SW Corbett Ave, Portland, OR 97239 Project #/PO#: **PR23514.002**

Lab # AP00088 coc 1 of _____

Sampled by: **Diane Spangler** ANALYSIS REQUEST

SAMPLE ID	LAB ID #	DATE	TIME	MATRIX	# OF CONTAINERS	200.8 Lead
SCOTT 01		07/13	1228	DW	1	
SCOTT 02		07/13	1234		1	
SCOTT 03		07/13	1239		1	
SCOTT 04		07/13	1246		1	
SCOTT 05		07/13	1249		1	
SCOTT 06		07/13	1253		1	
SCOTT 07		07/13	1258		1	
SCOTT 08		07/13	1250		1	
SCOTT 09		07/13	1230		1	
SCOTT 10		07/13	1244		1	

Normal Turn Around Time (TAT) 10 Business Days

TAT Requested (circle): 1 DAY 2 DAY 3 DAY 4 DAY 5 DAY Other: _____

SPECIAL INSTRUCTIONS:

RELINQUISHED BY: Signature: _____ Date: _____ RECEIVED BY: Signature: _____ Date: _____
 Printed Name: _____ Time: _____ Printed Name: _____ Time: _____
 Company: _____ Company: _____

SAMPLES ARE HELD FOR 30 DAYS

RELINQUISHED BY: Signature: _____ Date: 06/21/16 RECEIVED BY: Signature: _____ Date: _____
 Printed Name: _____ Time: 10:10 Printed Name: _____ Time: _____
 Company: FSS Company: _____

PBS Engineering and Environmental APEX

Apex Laboratories



Lisa Domenighini, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental
4412 SW Corbett Ave
Portland, OR 97239

Project: **Reynolds School-Scott**
Project Number: Reynolds SD #7 / PR23514.0
Project Manager: Rich Dufresne

Reported:
07/05/16 08:36

CHAIN OF CUSTODY

Lab # AP20168 coc 3 of _____

Project Mgr: Amanda Chanler Project Name: Reynolds SD #7 Project #/PO#: PR23514.022

Company: **PBS** Phone: (503) 248-1939 Fax: _____ Email: aglover@rsd7.net

4412 SW Corbett Ave, Portland, OR 97239

Sampled by: Larry Spangler

SAMPLE ID	LAB ID #	DATE	TIME	MATRIX	# OF CONTAINERS	2008 Lead	ANALYSIS REQUEST											
							1 DAY	2 DAY	3 DAY	4 DAY	5 DAY							
SC04 16		6/13/2016	09:20	DW	1													
SC04 17		6/13/2016	09:23		1													
SC04 18		6/13/2016	09:25		1													
SC04 19		6/13/2016	09:27		1													
SC04 20		6/13/2016	09:27		1													
SC04 21		6/13/2016	09:28		1													
SC04 22		6/13/2016	09:31		1													
SC04 23		6/13/2016	09:34		1													
SC04 24		6/13/2016	09:40		1													
SC04 25		6/13/2016	09:51		1													

Normal Turn Around Time (TAT) 10 Business Days

SPECIAL INSTRUCTIONS:

<p>TAT Requested (circle)</p> <p>1 DAY 2 DAY 3 DAY</p> <p>4 DAY 5 DAY Other: _____</p>	<p>RECEIVED BY:</p> <p>Signature: <u>[Signature]</u> Date: _____</p> <p>Printed Name: <u>Larry Spangler</u> Time: _____</p> <p>Company: <u>PBS</u></p>
<p>SAMPLES ARE HELD FOR 30 DAYS</p> <p>RECEIVED BY:</p> <p>Signature: <u>[Signature]</u> Date: <u>6/24/16</u></p> <p>Printed Name: <u>Larry Spangler</u> Time: <u>18:10</u></p> <p>Company: <u>PBS</u></p>	<p>RECEIVED BY:</p> <p>Signature: _____ Date: _____</p> <p>Printed Name: _____ Time: _____</p> <p>Company: _____</p>

PBS Engineering and Environmental

Apex Laboratories

Lisa Domenighini

Lisa Domenighini, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

PBS Engineering and Environmental
 4412 SW Corbett Ave
 Portland, OR 97239

Project: **Reynolds School-Scott**
 Project Number: Reynolds SD #7 / PR23514.0
 Project Manager: Rich Dufresne

Reported:
 07/05/16 08:36

CHAIN OF CUSTODY

APEX LABS 12232 S.W. Garden Place, Tigard, OR 97223 Ph: 503-718-2323 Fax: 503-718-0333

Company: **PBS** Project Mgr: **Amanda Govek** Project Name: **REYNOLDS SD #7** Project #/PO#: **PR23514.022**
 4412 SW Corbett Ave, Portland, OR 97239 Phone: (503) 248-1939 Fax: Email: **agovek@rystd.net**

Lab # **AP088** coc **4** of _____

Sampled by: **Larry Spangler**

SAMPLE ID	LAB ID #	DATE	TIME	MATRIX	# OF CONTAINERS	200.8 Lead	ANALYSIS REQUEST												
							1 DAY	2 DAY	3 DAY	4 DAY	5 DAY								
SOH 26	013	7/5/16	10:51	DW	1														
" 27	"	"	10:52	"	1														
" 28	"	"	10:53	"	1														
" 29	"	"	10:55	"	1														
" 30	"	"	20:01	"	1														
" 31	"	"	23:11	"	1														

SPECIAL INSTRUCTIONS:

Normal Turn Around Time (TAT) 10 Business Days

TAT Requested (circle): 1 DAY 2 DAY 3 DAY 4 DAY 5 DAY Other: _____

SAMPLES ARE HELD FOR 30 DAYS

RELINQUISHED BY: Signature: _____ Printed Name: Larry Spangler Company: ESS	RECEIVED BY: Signature: _____ Printed Name: Rich Dufresne Company: Apex
Date: 06/24/16	Date: _____
Time: 1:00	Time: _____
Company: ESS	Company: Apex

Apex Laboratories

Lisa Domenighini

Lisa Domenighini, Client Services Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.