GENERAL NOTES

- 1. ASBESTOS-CONTAINING MATERIALS ARE PRESENT IN ACCESSIBLE AND INACCESSIBLE INTERSTITIAL SPACES THROUGHOUT THIS BUILDING.
- ALL CONTRACTORS PERFORMING DEMOLITION ACTIVITIES ARE TO COMPLY WITH ALL APPLICABLE LEAD REGULATIONS IN OAR 437-DIVISION 3, 1926.62 AND SECTION 02 83 19 OF THE SPECIFICATIONS.
- CONTRACTOR IS TO COORDINATE ALL ABATEMENT ACTIVITIES WITH CONSTRUCTION MANAGER/GENERAL CONTRACTOR INCLUDING BUT NOT LIMITED TO: SCHEDULING, PHASING, ACCESS, AND SECURITY, POWER AND WATER NEEDS, PROTECT AND SAVE ITEMS, LOCKOUT/TAGOUT PROCEDURES AND SITE SAFETY REQUIREMENTS.
- THIS DRAWING IS DIAGRAMMATIC AND SHOULD BE USED FOR GENERAL MATERIAL INFORMATION AND SAMPLE LOCATIONS ONLY. CONTRACTOR IS TO FIELD VERIFY ALL MATERIAL LOCATIONS AND QUANTITIES.

ABATEMENT NOTES

- 1. ASBESTOS-CONTAINING BUILT-UP ROOFING, MASTIC, AND SHEATHING TO BE REMOVED FROM THROUGHOUT BUILDING.
- 2. ASBESTOS-CONTAINING ROOFING DEBRIS GENERATED DURING ROOFING REMOVAL TO BE CONTAINED AND REMOVED.
- 3. APPROXIMATELY 35 LEAD-CONTAINING VENT PIPE CAPS TO BE REMOVED.

KEY NOTES

DOOR WITH ASBESTOS-CONTAINING CAULK TO BE REMOVED.

LEGEND

WINDOWS WITH ASBESTOS-CONTAINING CAULK TO BE REMOVED

(1)

ASBESTOS SAMPLE SYMBOLS

OD7 DRAWING REFERENCE TO BULK SAMPLE FIELD CODE, SEE INVENTORY OF SAMPLES MATERIAL SYMBOL					
NOT TESTED	NEGATIVE	POSITIVE			
0	θ	•	THERMAL SYSTEM INSULATION		
			SURFACING MATERIAL		
٥	♦	•	MISCELLANEOUS MATERIAL		

INVENTORY OF ASBESTOS SAMPLES

DRAWING REFERENCE	FIELD CODE	LAB RESULT	MATERIAL SAMPLED
032	23514.174-0032	(-/-/-/-/+/+/+/+)	BUILT-UP ROOFING
033	23514.174-0033	(-/-/-/+/+/+/-/-/+)	BUILT-UP ROOFING
9 034	23514.174-0034	(-)	
036	23514.174-0036	(-/-/-/-/-/-)	BUILT-UP ROOFING
\$ 037	23514.174-0037	(-)	MASTIC
038	23514.174-0038	(+)	MASTIC



