GENERAL NOTES

- 1. ASBESTOS-CONTAINING MATERIALS ARE PRESENT IN ACCESSIBLE AND INACCESSIBLE INTERSTITIAL SPACES THROUGHOUT THIS BUILDING.
- 2. MATERIALS CONTAINING <1% ASBESTOS ARE PRESENT THROUGHOUT THE BUILDING. SEE HAZARDOUS MATERIALS SURVEY AND SPECIFICATION 02 82 21 FOR ADDITIONAL INFORMATION.
- 3. ALL CONTRACTORS PERFORMING DEMOLITION ACTIVITIES ARE TO COMPLY WITH ALL APPLICABLE LEAD REGULATIONS IN OAR 437-DIVISION 3, 1926.62 AND SECTION 02 83 19 OF THE SPECIFICATIONS.
- 4. CONTRACTOR IS TO COORDINATE ALL ABATEMENT ACTIVITIES WITH CONSTRUCTION MANAGER/GENERAL CONTRACTOR INCLUDING BUT NOT LIMITED TO: SCHEDULING, PHASING, ACCESS, AND SECURITY, POWER AND WATER NEEDS, PROTECT AND SAVE ITEMS, LOCKOUT/TAGOUT PROCEDURES AND SITE SAFETY REQUIREMENTS.
- 5. THIS DRAWING IS DIAGRAMMATIC AND SHOULD BE USED FOR GENERAL MATERIAL INFORMATION AND SAMPLE LOCATIONS ONLY. CONTRACTOR IS TO FIELD VERIFY ALL MATERIAL LOCATIONS AND QUANTITIES.

ABATEMENT NOTES

- 1. ADDITIONAL ASBESTOS-CONTAINING FLOORING IS PRESUMED TO EXIST UNDER WALL PLATES AND CASEWORK THROUGHOUT. CONTRACTOR IS TO FULLY REMOVE ALL ASBESTOS FLOORING THROUGHOUT.
- 2. APPROXIMATELY 20 MERCURY VAPOR LIGHT TUBES TO BE REMOVED.
- 3. CARPETING OVERLIES ASBESTOS FLOORING IN MOST LOCATIONS.

KEY NOTES

(1) MERCURY-CONTAINING SWITCH TO BE REMOVED.

LEGEND

ASBESTOS-CONTAINING FLOOR TILE AND MASTIC TO BE REMOVED

TWO-LAYERS OF ASBESTOS-CONTAINING FLOOR TILE AND MASTIC TO BE REMOVED

TWO-LAYERS OF ASBESTOS-CONTAINING SHEET FLOORING TO BE REMOVED

ASBESTOS SAMPLE SYMBOLS

DRAWING REFERENCE TO BULK SAMPLE FIELD CODE, SEE INVENTORY OF SAMPLES

—— MATERIAL SYMBOL

NOT NEGATIVE
TESTED
O 🖨

♦ 133

23514.174-0133 (-)

THERMAL SYSTEM INSULATION

SURFACING MATERIAL
MISCELLANEOUS MATERIAL

INVENTORY OF ASBESTOS SAMPLES

DRAWING REFERENCE	FIELD CODE	LAB RESULT	MATERIAL SAMPLED
♦ 100	23514.174-0100	(-/-/-)	VINYL FLOOR TILE/MASTIC
♦ 101	23514.174-0101		WALL AND CEILING PLASTER
♦ 102	23514.174-0102	• •	WALL AND CEILING PLASTER
♦ 103	23514.174-0103	(-)	WINDOW GLAZING COMPOUND
♦ 104	23514.174-0104	(-/-)	GYPSUM WALLBOARD
♦ 105	23514.174-0105	(-/-)	COVEBASE/MASTIC
1 06	23514.174-0106		VINYL FLOOR TILE/MASTIC
♦ 107	23514.174-0107	(-/-)	COVEBASE/MASTIC
♦ 108	23514.174-0108	(-/-/-)	VINYL FLOOR TILE/MASTIC
1 09	23514.174-0109	(<1%)	MASTIC
♦ 110	23514.174-0110	(-)	MASTIC
♦ 111	23514.174-0111	(-)	MASTIC
♦ 112	23514.174-0112	(-)	SHEET FLOOR COVERING
♦ 113	23514.174-0113	(-)	WALL AND CEILING PLASTER
♦ 114	23514.174-0114	(-)	ASPHALT IMPREGNATED PAPER
♦ 115	23514.174-0115	(-)	CERAMIC TILE GROUT
♦ 116	23514.174-0116	(-/-)	VINYL FLOOR TILE/MASTIC
♦ 117	23514.174-0117	(-/+/+/-/-)	SHEET FLOOR COVERING
♦ 118	23514.174-0118	` ,	VINYL FLOOR TILE/MASTIC
♦ 119	23514.174-0119	(-/<1%/+)	VINYL FLOOR TILE/MASTIC
♦ 120	23514.174-0120	(-)	BLOWN-IN INSULATION
♦ 121	23514.174-0121	(-)	BLOWN-IN INSULATION
♦ 122	23514.174-0122	(-)	BLOWN-IN INSULATION
♦ 123	23514.174-0123	(-/-/-)	GLUED-ON CEILING TILES
124	23514.174-0124	(-/<1%/+)	VINYL FLOOR TILE/MASTIC
125	23514.174-0125	(-/+/-/-/-)	SHEET FLOOR COVERING
♦ 126	23514.174-0126	(-/-)	WALL AND CEILING PLASTER
♦ 127	23514.174-0127	(-)	MORTAR
♦ 128	23514.174-0128	(-)	CEMENTITIOUS ROOF SHINGLES
♦ 129	23514.174-0129	(-)	CEMENTITIOUS ROOF SHINGLES
♦ 130	23514.174-0130	(-)	WINDOW GLAZING COMPOUND
♦ 131	23514.174-0131	(-)	ASPHALT IMPREGNATED PAPER
♦ 132	23514.174-0132	(-)	CAULK
/\ 400		/ \	

CAULK

LEAD SAMPLE SYMBOLS


DRAWING REFERENCE TO LEAD SAMPLE FIELD CODE, SEE INVENTORY OF SAMPLES


▲ LEAD DETECTED △ BELOW THE LIMIT OF DETECTION


INVENTORY OF AA LEAD SAMPLES

MATERIAL SYMBOL

SAMPLE NUMBER	FIELD CODE	LAB RESULT (ppm)	MATERIAL DESCRIPTION
▲1006	23514.174-1006	20.2	PAINT ON BUILDING B; BRICK MORTAR
▲1007	23514.174-1007	46,400	PAINT ON BUILDING B; WINDO
▲1008	23514.174-1008	2,750	PAINT ON BUILDING B; SIDING WOOD, BLUE








BASEMENT

FIRST FLOOR

SECOND FLOOR

BUILDING "B"



PBS Engineering Environmental Ir 4412 S Corbett Av Portland, OR 9723 503.248.1939 pbsusa.com

ATEMENT PLAN

| **TE**OD VILLAGE, OREGON

HAZARDOUS MATERIAL ABATEME

EDGEFIELD SITE

2345 NE 244TH AVENUE WOOD VII

SHEET DRAWING NO:

HA3

SHEET 3 OF 3