

# Water Testing Results - Alder Elementary

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen, island north sinks, east	21820100-001KF23A	6/7/2023	0.487
Kitchen, island, north sinks west	21820100-002KF23A	6/7/2023	1.06
Kitchen, island, south sinks	21820100-003KF23A	6/7/2023	0.999
Kitchen, west wall, sink	21820100-004KF23A	6/7/2023	1.59
Gym building second floor boy's restroom	21820100-005BF23A	6/7/2023	ND
Room 9	21820100-006CF23A	6/7/2023	1.6
Room 9	21820100-007DW23A	6/7/2023	0.79
Room 10	21820100-008CF23A	6/7/2023	3.01
Room 11	21820100-010CF23A	6/7/2023	5.22
Room 11	21820100-011DW23A	6/7/2023	1.25
Room 8	21820100-012CF23A	6/7/2023	4.36
Room 8	21820100-013DW23A	6/7/2023	0.56
Gym building second floor custodial office	21820100-014SF23A	6/7/2023	<b>66.7</b>
Room 12	21820100-015CF23A	6/7/2023	0.425
Room 12	21820100-016CF23A	6/7/2023	0.287
NW Hallway west hall	21820100-017DW23A	6/7/2023	ND
NW Hallway west hall	21820100-018WB23A	6/7/2023	ND
NW hallway boy's restroom	21820100-019BF23A	6/7/2023	2.14
NW hallway girl's restroom	21820100-020BF23A	6/7/2023	0.517
Room 7	21820100-021CF23A	6/7/2023	<b>110</b>
Room 13	21820100-022CF23A	6/7/2023	1.69
Room 13	21820100-023DW23A	6/7/2023	0.703
Room 14	21820100-024CF23A	6/7/2023	3.62
Room 14	21820100-025DW23A	6/7/2023	0.947
Room 6	21820100-026CF23A	6/7/2023	5.18
Room 6	21820100-027DW23A	6/7/2023	1.68
Room 5	21820100-028CF23A	6/7/2023	3.53
Room 15	21820100-030CF23A	6/7/2023	4.44

Room 15	21820100-031DW23A	6/7/2023	2.21
Room 4	21820100-032CF23A	6/7/2023	<b>13.2</b>
Room 4	21820100-033DW23A	6/7/2023	1.79
Room 3	21820100-034CF23A	6/7/2023	4.08
Room 3	21820100-035DW23A	6/7/2023	1.01
North hallway east side	21820100-036DW23A	6/7/2023	ND
North hallway east side	21820100-037WB23A	6/7/2023	ND
North hallway east girl's restroom	21820100-038BF23A	6/7/2023	0.638
North hallway east faculty restroom	21820100-039SF23A	6/7/2023	0.632
North hallway east boy's restroom	21820100-040BF23A	6/7/2023	1.28
Room 2	21820100-041CF23A	6/7/2023	8.83
Room 2	21820100-042DW23A	6/7/2023	1.04
Room 1	21820100-043CF23A	6/7/2023	11.8
Room 1	21820100-044DW23A	6/7/2023	9.36
Nurse	21820100-045NS23A	6/7/2023	6.31
Faculty restroom by nurse	21820100-046SF23A	6/7/2023	2.69
<b>Faculty work room</b>	<b>21820100-047SF23A</b>	6/7/2023	<b>193</b>
Teacher's lounge	21820100-048WB23A	6/7/2023	0.215
Teacher's lounge	21820100-049SF23A	6/7/2023	ND
Entry hall south	21820100-050WB23A	6/7/2023	ND
Entry hall south	21820100-051DW23A	6/7/2023	ND
South hall girl's restroom	21820100-052BF23A	6/7/2023	3.78
South hall boy's restroom	21820100-053BF23A	6/7/2023	2.02
Room 18	21820100-054CF23A	6/7/2023	1.21
Room 18	21820100-055DW23A	6/7/2023	1.13
Room 19	21820100-056CF23A	6/7/2023	1.58
Room 19	21820100-057DW23A	6/7/2023	2.91
Sun room restroom	21820100-058BF23A	6/7/2023	1.89
Sun room restroom	21820100-059BF23A	6/7/2023	0.776
Sun room	21820100-060CF23A	6/7/2023	0.479
Room 21	21820100-061CF23A	6/7/2023	1.87
Room 21	21820100-062DW23A	6/7/2023	0.663
Room 22	21820100-063CF23A	6/7/2023	1.13
Room 22	21820100-064DW23A	6/7/2023	0.799

Room 23	21820100-065CF23A	6/7/2023	1.04
Room 23	21820100-066DW23A	6/7/2023	4.56
Room 24	21820100-067DW23A	6/7/2023	1.8
Room 24	21820100-068DW23A	6/7/2023	1.34
South hall west side faculty restroom	21820100-069SF23A	6/7/2023	2.09
South hall west girls restroom	21820100-070BF23A	6/7/2023	4.96
South hall west	21820100-071WB23A	6/7/2023	ND
South hall west	21820100-072DW23A	6/7/2023	ND
South hall west	21820100-073DW23A	6/7/2023	ND
South hall west boy's restroom	21820100-074BF23A	6/7/2023	1.27
South hall west boy's restroom	21820100-075BF23A	6/7/2023	0.577
Room 25	21820100-076CF23A	6/7/2023	1.22
Room 25	21820100-077DW23A	6/7/2023	1.59
Room 26	21820100-078CF23A	6/7/2023	1.71
Room 26	21820100-079DW23A	6/7/2023	1.92
Room 27	21820100-080CF23A	6/7/2023	1.18
Room 27	21820100-081DW23A	6/7/2023	0.696
Room 28	21820100-082CF23A	6/7/2023	1.01
Room 28	21820100-083DW23A	6/7/2023	1.59
Room 29	21820100-084CF23A	6/7/2023	4.4
Room 29	21820100-085DW23A	6/7/2023	3.43
Room 30	21820100-086CF23A	6/7/2023	3.83
Room 30	21820100-087DW23A	6/7/2023	6.24
<b>Room 31</b>	<b>21820100-088CF23A</b>	6/7/2023	<b>30.8</b>
Room 10	21820100-009DW	6/7/2023	Not Tested
Room 5	21820100-029DW	6/7/2023	Not Tested

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing**

<b>RETESTS</b>			

ND = Non Detect - Lead level is below the set detection limits of 0.2 ppb			