

# Water Testing Results - Davis Elementary

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen, west	21820600-001KF23A	6/12/2023	ND
Kitchen, NE	21820600-002KF23A	6/12/2023	0.23
Kitchen, staff restroom	21820600-003SF23A	6/12/2023	2
Cafeteria	21820600-004WB23A	6/12/2023	ND
Restroom at counselor's office	21820600-007BF23A	6/12/2023	2.12
<b>Health/Nurse</b>	<b>21820600-008SF23A</b>	6/12/2023	<b>24.5</b>
Room 1	21820600-009CF23A	6/12/2023	1.84
Room 1	21820600-010DW23A	6/12/2023	1.62
Room 3	21820600-011CF23A	6/12/2023	3.4
Room 3	21820600-012DW23A	6/12/2023	2.49
Room 5	21820600-013CF23A	6/12/2023	2.71
Room 5	21820600-014DW23A	6/12/2023	2.72
Room 7	21820600-015CF23A	6/12/2023	7.33
Room 7	21820600-016DW23A	6/12/2023	2.65
Room 9	21820600-017CF23A	6/12/2023	0.988
Room 9	21820600-018DW23A	6/12/2023	1.43
Room 8	21820600-019CF23A	6/12/2023	2.55
Room 8	21820600-020DW23A	6/12/2023	2.8
Room 6	21820600-021CF23A	6/12/2023	0.503
Room 6	21820600-022DW23A	6/12/2023	3.21
Room 4	21820600-023CF23A	6/12/2023	2.08
Room 4	21820600-024DW23A	6/12/2023	3.57
Room 2	21820600-025CF23A	6/12/2023	1.26
Room 2	21820600-026DW23A	6/12/2023	2.79
SE Hall, west girl's restroom	21820600-027BF23A	6/12/2023	0.688
SE hall, west	21820600-028WB23A	6/12/2023	ND
SE hall, west	21820600-029DW23A	6/12/2023	ND
SE hall, west, boy's restroom	21820600-030BF23A	6/12/2023	0.279

Media Center	21820600-031BF23A	6/12/2023	5.51
<b>Title 1 Room</b>	<b>21820600-032CF23A</b>	6/12/2023	<b>31.9</b>
Title 1 Room	21820600-033DW23A	6/12/2023	<b>13.3</b>
North hall faculty restroom	21820600-034SF23A	6/12/2023	1.44
North hall faculty restroom	21820600-035SF23A	6/12/2023	0.662
Counselor's office	21820600-036WB23A	6/12/2023	ND
Counselor's office	21820600-037SF23A	6/12/2023	2.36
Room 16	21820600-038CF23A	6/12/2023	1.39
Room 16	21820600-039DW23A	6/12/2023	2.43
Room 18	21820600-040CF23A	6/12/2023	1.31
Room 18	21820600-041DW23A	6/12/2023	1.5
Room 20	21820600-042CF23A	6/12/2023	1.37
Room 20	21820600-043DW23A	6/12/2023	2.24
Room 22	21820600-044CF23A	6/12/2023	0.712
Room 22	21820600-045DW23A	6/12/2023	1.75
Teachers Lounge	21820600-046SF23A	6/12/2023	1.26
Teachers Lounge	21820600-047WB23A	6/12/2023	ND
Room 23	21820600-048CF23A	6/12/2023	4.72
Room 23	21820600-049DW23A	6/12/2023	3.14
North hall, east girl's restroom	21820600-050BF23A	6/12/2023	0.849
North hall, east	21820600-051WB23A	6/12/2023	ND
North hall, east	21820600-052DW23A	6/12/2023	ND
North hall, east boy's restroom	21820600-053BF23A	6/12/2023	0.719
Room 21	21820600-054CF23A	6/12/2023	4.8
Room 21	21820600-055DW23A	6/12/2023	1.71
Room 19	21820600-056CF23A	6/12/2023	3.09
Room 19	21820600-057DW23A	6/12/2023	2.51
Room 17	21820600-058CF23A	6/12/2023	2.3
Room 17	21820600-059DW23A	6/12/2023	2.75
Room 15	21820600-060CF23A	6/12/2023	0.934
Room 15	21820600-061CF23A	6/12/2023	1.57
Music Room	21820600-062CF23A	6/12/2023	7.87
Music Room	21820600-063DW23A	6/12/2023	1.75
North hall, west boy's restroom	21820600-064BF23A	6/12/2023	0.253

North hall, west	21820600-065WB23A	6/12/2023	ND
North hall, west	21820600-066DW23A	6/12/2023	ND
North hall, west girl's restroom	21820600-067BF23A	6/12/2023	1.46
North hall, west at gym	21820600-068WB23A	6/12/2023	ND
North hall, west at gym	21820600-069DW23A	6/12/2023	ND
Special ed north classroom restroom	21820600-070BF23A	6/12/2023	0.641
Special ed south classroom restroom	21820600-071BF23A	6/12/2023	0.34
Cafeteria	21820600-005DW	6/12/2023	Not Tested
Cafeteria	21820600-006DW	6/12/2023	Not Tested
<b>Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing</b>			
<b>RETESTS</b>			
ND = Non Detect - Lead level is below the set detection limits			of 0.2 ppb