

Water Testing Results - Glenfair Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen, SW corner	21820300-001KF23A	6/12/2023	2.38
Kitchen, staff restroom	21820300-002SF23A	6/12/2023	3.32
Kitchen, north wall	21820300-003KF23A	6/12/2023	0.569
Cafeteria	21820300-004WB23A	6/12/2023	ND
Cafeteria	21820300-005DW23A	6/12/2023	ND
Room 16 east restroom	21820300-006BF23A	6/12/2023	11.2
Room 16 workroom	21820300-007CF23A	6/12/2023	3.95
Room 16 workroom	21820300-008DW23A	6/12/2023	0.935
Room 16 west restroom	21820300-009BF23A	6/12/2023	3.92
Room 17 west restroom	21820300-010BF23A	6/12/2023	2.42
Room 17 workroom	21820300-011CF23A	6/12/2023	9.42
Room 17 workroom	21820300-012DW23A	6/12/2023	2.84
Room 17 east restroom	21820300-013BF23A	6/12/2023	4.61
Room 19 east restroom	21820300-014BF23A	6/12/2023	2.27
Room 19 workroom	21820300-015CF23A	6/12/2023	4.82
Room 19 workroom	21820300-016DW23A	6/12/2023	1.59
Room 19 west restroom	21820300-017BF23A	6/12/2023	1.59
Room 14 west restroom	21820300-018BF23A	6/12/2023	1.72
Room 14	21820300-019CF23A	6/12/2023	2.31
Room 14	21820300-020DW23A	6/12/2023	1.27
Room 14 east restroom	21820300-021BF23A	6/12/2023	1.02
Library	21820300-022CF23A	6/12/2023	6.59
Library	21820300-023DW23A	6/12/2023	0.809
Room 20	21820300-024CF23A	6/12/2023	10.1
Room 20	21820300-025DW23A	6/12/2023	2.12
West hall, north	21820300-026WB23A	6/12/2023	ND
West hall, north	21820300-027DW23A	6/12/2023	ND
Room 12 restroom	21820300-028BF23A	6/12/2023	1.72

Room 12	21820300-029CF23A	6/12/2023	2.09
Room 12	21820300-030DW23A	6/12/2023	1.19
Room 12 east restroom	21820300-031BF23A	6/12/2023	1.4
West hall, west leg boy's restroom	21820300-032BF23A	6/12/2023	2.41
West hall, west leg boy's restroom	21820300-033BF23A	6/12/2023	1.68
West hall, west leg faculty restroom	21820300-034SF23A	6/12/2023	0.557
West hall, west leg faculty restroom	21820300-035SF23A	6/12/2023	1.56
West hall, west leg room 23 restroom	21820300-036BF23A	6/12/2023	14.6
Gym	21820300-037WB23A	6/12/2023	ND
Gym	21820300-038DW23A	6/12/2023	ND
Room 11	21820300-039SF23A	6/12/2023	11.2
East hall boy's restroom	21820300-040BF23A	6/12/2023	0.394
East hall boy's restroom	21820300-041BF23A	6/12/2023	ND
East hall boy's restroom	21820300-042BF23A	6/12/2023	0.383
East hall girl's restroom	21820300-044BF23A	6/12/2023	ND
East hall, west	21820300-045WB23A	6/12/2023	ND
East hall, west	21820300-046DW23A	6/12/2023	ND
Room 10	21820300-048CF23A	6/12/2023	2.05
Room 10	21820300-049DW23A	6/12/2023	3.49
Room 9	21820300-050CF23A	6/12/2023	1.51
Room 9	21820300-051DW23A	6/12/2023	1.35
Room 8	21820300-052CF23A	6/12/2023	3.74
Room 8	21820300-053DW23A	6/12/2023	2.07
Room 7	21820300-054CF23A	6/12/2023	8.46
Room 7	21820300-055DW23A	6/12/2023	0.84
East hall basement classroom	21820300-056CF23A	6/12/2023	0.601
East hall basement classroom	21820300-057DW23A	6/12/2023	0.349
East hall basement classroom restroom	21820300-058BF23A	6/12/2023	0.899
East hall basement classroom restroom	21820300-059BF23A	6/12/2023	1.23
East hall basement classroom	21820300-060CF23A	6/12/2023	0.784
East hall basement classroom	21820300-061DW23A	6/12/2023	0.209
Room 6	21820300-062CF23A	6/12/2023	6.88
Room 6	21820300-063DW23A	6/12/2023	2.22
Room 5	21820300-064CF23A	6/12/2023	7.11

Room 5	21820300-065DW23A	6/12/2023	2.42
Room 4	21820300-066CF23A	6/12/2023	3.67
Room 4	21820300-067DW23A	6/12/2023	0.578
Room 3	21820300-068CF23A	6/12/2023	6.75
Room 3	21820300-069DW23A	6/12/2023	2.03
Room 2	21820300-070CF23A	6/12/2023	5.43
Room 2	21820300-071DW23A	6/12/2023	2.52
Teachers lounge	21820300-072SF23A	6/12/2023	0.962
Teachers lounge	21820300-073WB23A	6/12/2023	ND
Nurses office restroom	21820300-074NS23A	6/12/2023	1.46
East hall girl's restroom	21820300-043BF	6/12/2023	Not Sampled
East hall west drinking fountain	21820300-047DW	6/12/2023	Not Sampled

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			

ND = Non Detect - Lead level is below the set detection limits of 0.2 ppb