

# Water Testing Results - Hartley Elementary

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen SE	21820400-001KF23A	6/16/2023	0.48
Kitchen staff sink near restroom	21820400-002SF23A	6/16/2023	3.57
Kitchen north	21820400-003KF23A	6/16/2023	3.97
Hall to kitchen, staff restroom	21820400-004SF23A	6/16/2023	0.838
Hall to kitchen, staff restroom	21820400-005SF23A	6/16/2023	0.773
<b>Workroom</b>	<b>21820400-006CF23A</b>	6/16/2023	<b>15.2</b>
Gym hallway	21820400-007WB23A	6/16/2023	ND
Gym hallway	21820400-008DW23A	6/16/2023	ND
Room 14	21820400-009CF23A	6/16/2023	2.6
Room 16	21820400-010CF23A	6/16/2023	4.15
Room 16	21820400-011DW23A	6/16/2023	1.29
Room 18	21820400-012CF23A	6/16/2023	3.01
Room 18	21820400-013DW23A	6/16/2023	1.9
Room 20	21820400-014CF23A	6/16/2023	0.265
Room 20	21820400-015DW23A	6/16/2023	2.8
Room 21	21820400-016CF23A	6/16/2023	0.679
Room 21	21820400-017DW23A	6/16/2023	1.88
Room 19	21820400-018CF23A	6/16/2023	0.859
Room 19	21820400-019DW23A	6/16/2023	1.52
Room 17	21820400-020CF23A	6/16/2023	1.17
Room 17	21820400-021DW23A	6/16/2023	1.81
1 <sup>st</sup> /2 <sup>nd</sup> grade hall boys restroom	21820400-022BF23A	6/16/2023	2.49
1 <sup>st</sup> /2 <sup>nd</sup> grade hall	21820400-023WB23A	6/16/2023	ND
1 <sup>st</sup> /2 <sup>nd</sup> grade hall	21820400-024DW23A	6/16/2023	ND
1 <sup>st</sup> /2 <sup>nd</sup> grade hall girls restroom	21820400-025BF23A	6/16/2023	3.5
Teachers lounge	21820400-026SF23A	6/16/2023	1.34
Teachers lounge	21820400-027WB23A	6/16/2023	ND
SE hall boys restroom	21820400-028BF23A	6/16/2023	4.28

SE hall boys restroom	21820400-029BF23A	6/16/2023	5.32
SE hall	21820400-030WB23A	6/16/2023	ND
SE hall	21820400-031DW23A	6/16/2023	ND
SE hall girls restroom	21820400-032BF23A	6/16/2023	5.5
Room 2	21820400-033CF23A	6/16/2023	3.18
Room 2	21820400-034DW23A	6/16/2023	1.56
Room 4	21820400-035CF23A	6/16/2023	1.94
Room 4	21820400-036DW23A	6/16/2023	1.03
Room 6	21820400-037CF23A	6/16/2023	8.28
Room 6	21820400-038DW23A	6/16/2023	2.46
Room 8	21820400-039CF23A	6/16/2023	4.41
Room 8	21820400-040DW23A	6/16/2023	0.75
Room 10	21820400-041CF23A	6/16/2023	0.834
Room 10	21820400-042DW23A	6/16/2023	1.12
South hall boys restroom	21820400-043BF23A	6/16/2023	4.45
South hall	21820400-044WB23A	6/16/2023	ND
South hall	21820400-045DW23A	6/16/2023	ND
South hall girls restroom	21820400-046BF23A	6/16/2023	2.63
Room 15	21820400-047CF23A	6/16/2023	5.89
Room 15	21820400-048DW23A	6/16/2023	0.705
Room 13	21820400-049CF23A	6/16/2023	10.2
Room 13	21820400-050DW23A	6/16/2023	0.612
Room 11	21820400-051CF23A	6/16/2023	1.96
Room 11	21820400-052DW23A	6/16/2023	0.515
Room 9	21820400-053CF23A	6/16/2023	3.22
Room 9	21820400-054DW23A	6/16/2023	2.48
Room 7	21820400-055CF23A	6/16/2023	8.54
Room 5	21820400-056CF23A	6/16/2023	2.51
Room 5	21820400-057DW23A	6/16/2023	4.97
Room 3	21820400-058CF23A	6/16/2023	0.685
Room 3	21820400-059DW23A	6/16/2023	0.414
Room 1	21820400-060CF23A	6/16/2023	1.41
Room 1	21820400-061DW23A	6/16/2023	1.6
Front office staff restroom west	21820400-062BF23A	6/16/2023	0.473

Nurses office	21820400-063NS23A	6/16/2023	0.904
Front office staff restroom east	21820400-064SF23A	6/16/2023	0.297
Cafeteria	21820400-065WB23A	6/16/2023	ND
Cafeteria	21820400-066DW23A	6/16/2023	ND
Cafeteria	21820400-067DW23A	6/16/2023	ND
Pod C restroom	21820400-068BF23A	6/16/2023	2.04
Pod D restroom	21820400-069BF23A	6/16/2023	1.02
North pod	21820400-070CF23A	6/16/2023	1.7
North pod	21820400-071DW23A	6/16/2023	0.394
North pod restroom	21820400-073BF23A	6/16/2023	0.831
North pod restroom	21820400-074BF23A	6/16/2023	3.32
North pod classroom	21820400-075CF23A	6/16/2023	0.905
North Pod	21820400-072DW	6/16/2023	Not Sampled
<b>Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing</b>			
<b>RETESTS</b>			
ND = Non Detect - Lead level is below the set detection limits			of 0.2 ppb