

Water Testing Results - Margaret Scott

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen, NE wall sink	21820500-001KF23A	6/16/2023	16.3
Kitchen staff restroom	21820500-002SF23A	6/16/2023	3.27
Kitchen west	21820500-003KF23A	6/16/2023	0.383
Kitchen center	21820500-004KF23A	6/16/2023	0.551
Kitchen center	21820500-005KF23A	6/16/2023	0.833
Kitchen center	21820500-006KF23A	6/16/2023	0.501
Cafeteria	21820500-007WB23A	6/16/2023	ND
Cafeteria	21820500-008DW23A	6/16/2023	ND
Cafeteria	21820500-009DW23A	6/16/2023	ND
West hall, boys restroom	21820500-010BF23A	6/16/2023	1.31
Room 11	21820500-012CF23A	6/16/2023	9.16
Room 12	21820500-013CF23A	6/16/2023	3.27
West hall	21820500-014WB23A	6/16/2023	ND
West hall	21820500-015DW23A	6/16/2023	ND
Room 13	21820500-016CF23A	6/16/2023	6.96
Room 14	21820500-017CF23A	6/16/2023	6
West hall girls restroom	21820500-018BF23A	6/16/2023	1.81
West hall girls restroom	21820500-019BF23A	6/16/2023	0.735
Teachers lounge	21820500-020WB23A	6/16/2023	ND
Teachers lounge	21820500-021SF23A	6/16/2023	0.203
Teachers lounge staff restroom	21820500-022SF23A	6/16/2023	0.709
Teachers lounge staff restroom	21820500-023SF23A	6/16/2023	1.19
Nurses office restroom	21820500-024NS23A	6/16/2023	1.3
Learning center (room 10)	21820500-025CF23A	6/16/2023	5.68
Main center hall	21820500-026WB23A	6/16/2023	ND
Main center hall	21820500-027DW23A	6/16/2023	ND
East hall boys restroom	21820500-028BF23A	6/16/2023	ND
East hall	21820500-029WB23A	6/16/2023	ND

East hall	21820500-030DW23A	6/16/2023	ND
East hall girls restroom	21820500-031BF23A	6/16/2023	ND
Room 10	21820500-032CF23A	6/16/2023	0.371
Room 9	21820500-033CF23A	6/16/2023	5.28
Room 8	21820500-034CF23A	6/16/2023	2
Hall outside Room 7	21820500-035WB23A	6/16/2023	ND
Hall outside Room 7	21820500-036DW23A	6/16/2023	ND
Room 7	21820500-037CF23A	6/16/2023	2.06
Restroom outside Room 7	21820500-038BF23A	6/16/2023	1.44
Room 6	21820500-039CF23A	6/16/2023	8.48
Restroom outside Room 6	21820500-040BF23A	6/16/2023	1.06
Computer room, south office	21820500-041SF23A	6/16/2023	27.6
Restroom outside Room 5	21820500-042BF23A	6/16/2023	2.37
Room 5	21820500-043BF23A	6/16/2023	2.14
Restroom outside Room 4	21820500-044BF23A	6/16/2023	0.967
Room 4	21820500-045CF23A	6/16/2023	2.62
Hall outside Room 4	21820500-046WB23A	6/16/2023	ND
Hall outside Room 4	21820500-047DW23A	6/16/2023	ND
Room 3	21820500-048CF23A	6/16/2023	0.981
Room 2	21820500-049CF23A	6/16/2023	6.42
Room 1	21820500-050CF23A	6/16/2023	4.68
Restroom outside Room 1	21820500-051BF23A	6/16/2023	1.56
Restroom outside Room 1	21820500-052BF23A	6/16/2023	2.58
Pod classroom, west classroom	21820500-053CF23A	6/16/2023	3.74
Pod classroom, west classroom	21820500-054DW23A	6/16/2023	ND
Pod classroom, west restroom	21820500-055BF23A	6/16/2023	1.32
Pod classroom, east restroom	21820500-056BF23A	6/16/2023	0.59
Pod classroom, east classroom	21820500-057CF23A	6/16/2023	2.29
3 rd /4 th grade pod hallway	21820500-058CF23A	6/16/2023	1.08
3 rd /4 th grade pod hallway	21820500-059DW23A	6/16/2023	ND
3 rd /4 th grade pod hallway	21820500-060DW23A	6/16/2023	ND
3 rd /4 th grade pod girls restroom	21820500-061BF23A	6/16/2023	1.17
3 rd /4 th grade pod girls restroom	21820500-062BF23A	6/16/2023	0.836

3 rd /4 th grade pod boys restroom	21820500-063BF23A	6/16/2023	0.927
3 rd /4 th grade pod boys restroom	21820500-064BF23A	6/16/2023	0.843
Gym girls restroom	21820500-065BF23A	6/16/2023	3.77
Gym girls restroom	21820500-066BF23A	6/16/2023	4.48
Gym	21820500-067WB23A	6/16/2023	ND
Gym	21820500-068DW23A	6/16/2023	ND
Gym boys restroom	21820500-069BF23A	6/16/2023	2.43
Gym boys restroom	21820500-070BF23A	6/16/2023	2.73
West hall north boy's restroom sink (south tap)	21820500-011BF	6/16/2023	Not Tested
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits			of 0.2 ppb