

Water Testing Results - Salish Ponds

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen, staff handwashing	22821700-001SF23A	6/19/2023	2.26
Kitchen, SE food prep (east)	22821700-002KF23A	6/19/2023	17.3
Kitchen, SE food prep (west)	22821700-003KF23A	6/19/2023	10
Kitchen, dishwashing	22821700-004KF23A	6/19/2023	0.678
Kitchen, south, west sink	22821700-005KF23A	6/19/2023	0.686
Kitchen, restroom	22821700-006SF23A	6/19/2023	1.06
Cafeteria west bathroom	22821700-007BF23A	6/19/2023	3.41
Cafeteria south bathroom	22821700-008BF23A	6/19/2023	1.09
Cafeteria (left)	22821700-009DW23A	6/19/2023	ND
Cafeteria	22821700-010WB23A	6/19/2023	ND
Cafeteria (right)	22821700-011DW23A	6/19/2023	ND
Girl's restroom, south hallway (south)	22821700-012BF23A	6/19/2023	9.03
Girl's restroom, south hallway (center)	22821700-013BF23A	6/19/2023	4.39
Girl's restroom, south hallway (north)	22821700-014BF23A	6/19/2023	4.58
Restroom, east hallway (left)	22821700-015BF23A	6/19/2023	0.923
Restroom, east hallway (right)	22821700-016BF23A	6/19/2023	3.66
Room 9	22821700-017CF23A	6/19/2023	1.24
Room 11	22821700-018CF23A	6/19/2023	2.22
Hall near Room 11	22821700-019DW23A	6/19/2023	ND
Hall near Room 11	22821700-020WB23A	6/19/2023	ND
Room 13	22821700-021CF23A	6/19/2023	0.921
Room 15	22821700-022CF23A	6/19/2023	1.92
Room 14	22821700-023CF23A	6/19/2023	1.02
Room 12	22821700-024CF23A	6/19/2023	1.09
Room 10	22821700-025CF23A	6/19/2023	1.06
Room 2	22821700-026CF23A	6/19/2023	2.05
Room 4	22821700-027CF23A	6/19/2023	0.861
Hall near Room 4	22821700-028DW23A	6/19/2023	ND

Hall near Room 4	22821700-029WB23A	6/19/2023	ND
Room 6	22821700-030CF23A	6/19/2023	1.91
Room 7	22821700-031CF23A	6/19/2023	1.15
Room 5	22821700-032CF23A	6/19/2023	1.12
Room 3	22821700-033CF23A	6/19/2023	1.19
Room 1	22821700-034CF23A	6/19/2023	1.42
Utility sink in commons hallway	22821700-035OT23A	6/19/2023	2.38
Commons hallway girl's restroom (north)	22821700-036BF23A	6/19/2023	0.69
Commons hallway girl's restroom (center)	22821700-037BF23A	6/19/2023	1
Commons hallway girl's restroom (south)	22821700-038BF23A	6/19/2023	1.6
Common hallway, north	22821700-039DW23A	6/19/2023	ND
Common hallway, north	22821700-040WB23A	6/19/2023	ND
Common hallway boy's restroom (north)	22821700-041BF23A	6/19/2023	0.586
Common hallway boy's restroom (center)	22821700-042BF23A	6/19/2023	1.19
Common hallway boy's restroom (south)	22821700-043BF23A	6/19/2023	1.79
Main office	22821700-044WB23A	6/19/2023	ND
Nurses office restroom	22821700-045NS23A	6/19/2023	0.204
Room 19	22821700-046CF23A	6/19/2023	2.55
Room 20	22821700-047CF23A	6/19/2023	1.93
Teachers lounge	22821700-048SF23A	6/19/2023	0.578
Teachers lounge	22821700-049WB23A	6/19/2023	ND
Teachers lounge restroom	22821700-050SF23A	6/19/2023	0.55
Room 18 bathroom	22821700-051BF23A	6/19/2023	0.705
Room 18	22821700-052DW23A	6/19/2023	0.441
Room 18	22821700-053CF23A	6/19/2023	0.695
Room 17	22821700-054CF23A	6/19/2023	1.88
West hallway girls' restroom (south sink)	22821700-057BF23A	6/19/2023	1.15
West hallway girls' restroom (south sink)	22821700-058BF23A	6/19/2023	0.921
West hallway girls' restroom (north sink)	22821700-059BF23A	6/19/2023	0.635
West hallway girls' restroom (north sink)	22821700-060BF23A	6/19/2023	0.909
West hallway	22821700-061WB23A	6/19/2023	ND
West hallway	22821700-062DW23A	6/19/2023	ND
West hallway boy's restroom (south sink)	22821700-063BF23A	6/19/2023	1.07
West hallway boy's restroom (south sink)	22821700-064BF23A	6/19/2023	0.87

West hallway boy's restroom (north sink)	22821700-065BF23A	6/19/2023	0.827
West hallway boy's restroom (north sink)	22821700-066BF23A	6/19/2023	0.292
Upstairs boy's restroom (south sink)	22821700-067BF23A	6/19/2023	1.42
Upstairs boy's restroom (south sink)	22821700-068BF23A	6/19/2023	1.34
Upstairs boy's restroom (north sink)	22821700-069BF23A	6/19/2023	1.23
Upstairs boy's restroom (north sink)	22821700-070BF23A	6/19/2023	0.57
Upstairs hallway	22821700-071WB23A	6/19/2023	ND
Upstairs hallway	22821700-072DW23A	6/19/2023	ND
Upstairs girls' restroom (south sink)	22821700-073BF23A	6/19/2023	2.57
Upstairs girls' restroom (south sink)	22821700-074BF23A	6/19/2023	2.12
Upstairs girls' restroom (north sink)	22821700-075BF23A	6/19/2023	1.81
Upstairs girls' restroom (north sink)	22821700-076BF23A	6/19/2023	0.678
Room 23	22821700-077CF23A	6/19/2023	2.05
Room 24	22821700-078CF23A	6/19/2023	0.954
Room 26	22821700-079CF23A	6/19/2023	1.47
Room 25	22821700-080CF23A	6/19/2023	5.61
Gym hall	22821700-055WB	6/19/2023	Not Tested
Gym hall	22821700-056DW	6/19/2023	Not Tested
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
ND = Non Detect - Lead level is below the set detection limits			of 0.2 ppb